



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 06, 2022
Client: Ogdensburg Borough BOE
Address: 100 Main Street
Ogdensburg, NJ 07439

PWSID#:
Project Location:

Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	220421016-001						
Sample Location:	Field Blank	Customer Sample Number:							
Sampled By:	Z. Shortway								
Sample Date/Time:	4/22/2022 7:06								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	11:09	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220421016-002						
Sample Location:	Main Office Water Ftn	Customer Sample Number:							
Sampled By:	Z. Shortway								
Sample Date/Time:	4/22/2022 7:07								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	13:13	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220421016-004							
Sample Location: Breezeway Water Ftn		Customer Sample Number:							
Sampled By: Z. Shortway									
Sample Date/Time: 4/22/2022 7:11									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	13:35	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220421016-005							
Sample Location: Breezeway Bottle Fill		Customer Sample Number:							
Sampled By: Z. Shortway									
Sample Date/Time: 4/22/2022 7:12									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	13:40	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220421016-006							
Sample Location: Kitchen Sink		Customer Sample Number:							
Sampled By: Z. Shortway									
Sample Date/Time: 4/22/2022 7:15									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	17.9 **	µg/L	15	4/29/2022	13:46	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220421016-007							
Sample Location: Room 303 Faucet		Customer Sample Number:							
Sampled By: Z. Shortway									
Sample Date/Time: 4/22/2022 7:17									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.12	µg/L	15	4/29/2022	14:19	JGW	2	1

Sample Matrix: Drinking Water	Lab Sample Number: 220421016-008
Sample Location: Room 303 Bubbler	Customer Sample Number:
Sampled By: Z. Shortway	
Sample Date/Time: 4/22/2022 7:18	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	14:25	JGW	2	1

Sample Matrix: Drinking Water	Lab Sample Number: 220421016-009
Sample Location: Room 304 Faucet	Customer Sample Number:
Sampled By: Z. Shortway	
Sample Date/Time: 4/22/2022 7:20	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	14:30	JGW	2	1


Sample Matrix: Drinking Water	Lab Sample Number: 220421016-010
Sample Location: Room 304 Bubbler	Customer Sample Number:
Sampled By: Z. Shortway	
Sample Date/Time: 4/22/2022 7:21	

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	4/29/2022	14:35	JGW	2	1

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.
 NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.



 Susan VanVeen, Laboratory Manager

_____ May 06, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220421016
220421016

Customer Name:	Ogdensburg Borough BOE	Report to:	Sean MacLeod	Agra Environmental Services	# Asc./HCl Vials pH: _____
Location:				90 1/2 West Blackwell Street	# HCl Vials pH: _____
Address:	100 Main Street			Dover, NJ 07801	# Na ₂ S ₂ O ₈ Cl ₂ : _____
	Ogdensburg, NJ, 07439			Phone: (973) 989-0010	# HNO ₃ pH: _____
Customer Contact:	Sean MacLeod	smacleod@obboe.org		Fax: (973) 989-0156	# H ₂ SO ₄ pH: _____
Phone: Work/Cell	/ 973-725-9966				# NaOH pH: _____
					# unpreserved _____
					# other _____
					# other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 1

Project: Lead Testing BOE		Collection		PWSID#		for laboratory use only				Field Analysis	
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220421016-001	Field Blank	4/22/22	0706	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-002	Main Office Water Ftn		0707	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-003	Main Office Bottle Fill			X		DW	1	HNO ₃	Lead-1st Draw		is the no sample
220421016-004	Breezeway Water Ftn		0711	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-005	Breezeway Bottle Fill		0712	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-006	Kitchen Sink		0715	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-007	Room 303 Faucet		0717	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-008	Room 303 Bubbler		0718	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-009	Room 304 Faucet		0720	X		DW	1	HNO ₃	Lead-1st Draw		
220421016-010	Room 304 Faucet Bubbler		0721	X		DW	1	HNO ₃	Lead-1st Draw		

Sampled By (name/company): <i>Zach Shortway / Agra</i>	Are these samples for compliance? (circle one): Yes or No	Indicate laboratory location where analysis request was performed
	NJDEP Laboratory Certification (Dover, NJ) #14013	
	NJDEP Laboratory Certification (Marlboro, NJ) #13033	
Reporting Requirements (Check Box):	Standard	NJ Reduced
		Other (Specify)
		Cooler Temperature Upon Receipt at lab:

Sample Custody Exchanges (Please use full legal signature)						Comments:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	<i>Main office Bottle Fill Broken-out of</i> <i>* Pres. with H₂O₃ 4/22/22 0825</i> <i>Service</i> <i>Z Shortway</i>
<i>Z Shortway</i>	4/22/22	0830	<i>Shelley</i>	4/22/22	0841	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Date Faxed _____
						Invoice Number _____
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	Is sample known to be hazardous? (circle one)
						Yes or No